



Health and Safety
Executive



Environment
Agency

Other Issues to Consider

Dave Watson

Nuclear Directorate

Potential Operators Seminar, Aintree 26 February 2008

Safety Case

- The safety case is for the Operator not the Regulator
- Tech Specs and the Maintenance schedule are derived from the safety case
- Safety Case is a living suite of documents It must be:
 - Understood
 - Referred to daily
 - Adhered to
 - Reviewed & Updated

Licence Conditions

- All LCs apply from Day 1 but are applied proportionately eg Emergency Plan
- They apply to everyone on the site – Board members, cleaners, contractors
- LC 36 covers Organisational Change. This means changes cannot be made to the Baseline Licensee Organisation unless a safety assessment is undertaken by licensee. NII can stop organisation changes.



Health and Safety
Executive



Environment
Agency

Other issues

- It will help potential licensees to become intelligent operators if both the vendors & licensees have a strong UK presence
- Radwaste storage and treatment facilities and spent fuel management are key parts of GDA