

HEALTH AND SAFETY EXECUTIVE
PRESSURE SYSTEMS SAFETY REGULATIONS 2000
CERTIFICATE OF EXEMPTION No.1 OF 2021


In accordance with the powers conferred upon it by paragraph (1) of regulation 17 of The Pressure Systems Safety Regulations 2000 (“the Regulations”) (SI 2000/128) and being satisfied that the health and safety of persons who are likely to be affected by the exemption will not be prejudiced in consequence of it as required by paragraph (2) of that regulation, the Health and Safety Executive (“the Executive”) grants the following Certificate of Exemption (“exemption”).

EXEMPTION

The Regulations shall not apply to any pressure system forming an enclosure for high voltage electrical equipment.

This exemption takes effect from **1st December 2021** and shall remain in force for five years, subject to the power of the Executive to vary or revoke it at any time by a further certificate in writing.

Signed by:

A handwritten signature in black ink, appearing to read 'P. R. Brown', is written over a light grey rectangular background.

Director of Engagement and Policy Division of the Executive who has been duly authorised by the Executive to sign on its behalf Mr Peter Brown.

Dated: 28 September 2021